


## CERTIFICATE

The School building of Shining Star Global (Thural), Teh. Thural in Distt. Kangra (H.P.) was inspected by the concerned Junior Engineer on dated.13/11/2025. As per the report of Junior Engineer this building has neither been designed nor been constructed by this office. No earth quake resistant norms have been adopted for this building .No structural drawings approved by the competent Govt. agency have been produced. No structure is a Non-Engineer structure, hence the structural safety of this building cannot be ensured specifically from earth quake point of view. This department will not be responsible for any type of loss of life and property etc. if this structure fails under any circumstances. However as per visual inspection the building has been found to be safe at present only. NO Officer/Official of this office will attend/plead in any Hon'ble Court of law in case of any dispute.


Note:- This Certificate is valid for one year from the issue date.

Place: - Thural

Dated: - 13/11/2025.

  
Junior Engineer,  
Thural Sub-Division,  
HP.PWD Thural.

  
Assistant Engineer,  
Thural Sub-Division,  
HP.PWD Thural

  
Executive Engineer,  
Bhawarna Division,  
HP,PWD Bhawarna.